



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-9A	TRIPPED ON OLR	RESET DONE	10:03:00	10:15:00	
2	OHP	BRC ON CO-30`	BC TRIPPED	RESET DONE	09:20:00	09:30:00	
3	OHP	co-23 tbs	no power	3 ht fuse blown	13:45:00	14:00:00	
4	CHP	CC-45	TRIPPED ON OLR	RESET DONE	09:53:00 10:30:00	10:00:00 10:35:00	
5	CHP	CC-51	MPD TRIPPED 14 TIMES	RESET DONE	07:09:00	13:11:00	
6	CHP	CC-54	TRIP 16 TIMES	RESET DONE	08:35:00	12:56:00	
7	CHP	CC-117	TRIPPED ON OLR	RESET DONE	08:17:00	08:25:00	
8	WT	PC-8	REV L/S ACTED	RELEASED	10:45:00	10:55:00	