



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 11/12/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	06:50:00	07:00:00	
2	OHP	BRC on CO-8A	Reported B/W-1 ZSS acting	Jamming found in both B/W-1,2 chute	06:45:00	07:00:00	Informed to operation
3	OHP	BRC on CO-8A	Reported B/W-2 not rotating	Stone stuck up	08:50:00	09:10:00	Informed to operation
4	OHP	WOBR on CO-29	Reported slewing not taking place	Drive tripped.Reset done	10:50:00	11:10:00	
5	OHP	CO-29	Reported tripped	OLR acted.Reset done	11:20:00	11:30:00	
6	CHP	CC 31 SCR-4	LT not taking place	Wrong complaint	06:55:00	07:10:00	
7	CHP	CC 125	Reported tripped	OLR acted.Reset done	08:14:00	08:19:00	
8	CHP	CC 34 SCR-1	Slew not taking place	Control MCB tripped.Made on	11:43:00	11:55:00	
9	CHP	CC 40 SCR-2	Slew not taking place	Drive tripped.Reset done	12:00:00	12:10:00	
10	CHP	Cc-51	MPD tripped	Feeding conveyor stopped.Reset done(8 times)	08:00:00	12:00:00	
11	CHP	Cc-53	Reported tripped	MPCB tripped.Made on	09:00:00	09:15:00	
12	CHP	Cc-22(B/D)	Reported tripped	OLR acted.Reset done	10:00:00	10:10:00	