



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/05/2025

Area: IOSA

Equipment	Job
MISC	OC-27A and 36A H/E and T/E CABLE TRAY WELDING DONE AND CABLE DRESSING DONE.
WOBR (L and T)	LT, BUCKET WHEEL and SLEW NOT WORKING . FOUND LT NOT TAKING PLACE DUE TO RAIL UNIT OIL LEVEL LOW.SLEW and BUCKET WHEEL FAULT IS OIL LEVEL LOW.
OC-11A	RADIO MODEM UNIT PANEL PPM DONE.
OC-29A	MOTOR AND FIELD DEVICES PPM DONE