



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	REPORTED BRS NOT HEALTHY FOUND GLASS FUSE BLOWN IN BRS PENAL	GLASS FUSE REPLACED THAN BRS RESET DONE	06:45:00	07:10:00	
2	OHP	TBS ON CO-22	REPORTED C/S NOT WORKING CHECKED WITH INSTRUMENTATION PRESENCE	COMMUNICATION PROBLEM THAN CLEARANCE GIVEN	09:00:00	09:20:00	
3	OHP	CO-63	TRIPPED ON OLR	RESET DONE	11:10:00	11:20:00	
4	OHP	CO-27A	REPORTED PULL CHORD NOT HEALTHY FOUND P/C OPERATED	PULL CHORD RESET DONE THAN OK	12:00:00	12:10:00	
5	CHP	CC-54	TRIPPED ON OLR (20TIMES)	RESET DONE	07:00:00	13:50:00	
6	CHP	CC-51	MPD TRIP (15TIMES) FEEDING CONVEYOR STOP	RESET DONE	09:00:00	13:30:00	
7	CHP	CC-38 SCR-6	REPORTED B/C STOPPING FREQUENTLY CHECKED AND FOUND SIGNAL PROBLEM	INTERLOCK ZSS KEPT IN LINE THAN OK	11:30:00	11:40:00	
8	CHP	CC-125	TRIPPED ON OLR	RESET DONE	12:15:00	12:25:00	
9	WT	ALL PUSHERS	REPORTED NOT MOVE COMMUNICATION PROBLEM	POWER RE-CYCLE LC-1, 2B	11:00:00	12:00:00	