



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-24	L/LUFF NOT TAKING PLACE OLR ACTED	OLR RESET	15:10:00	15:20:00	
2	OHP	TBS ON CO-7A	L/LUFF OLR ACTED	OLR RESET DONE	15:30:00	15:40:00	
3	OHP	BRC ON CO-34	REPORTED LT SKEW ACTED	SKEW ADJUSTED WITH MECHANICAL THAN LT OK	17:30:00	18:30:00	
4	OHP	BRC ON CO-31	LT NOT TAKING PLACE M-5 OLR ACTED	M-5 OLR RESET DONE	19:10:00	19:20:00	DUE TO TRACK JAMMING
5	OHP	BRC ON CO-31	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	21:20:00	21:30:00	
6	CHP	CC-31 SCR-4	B/C DISCHARGE CHUTE SENSOR ACTED CHECKED AND FOUND PROBE CABLE DAMAGE	PROBE CABLE CLEANING AND PROPER TAPPING WAS DONE THAN OK	19:20:00	19:30:00	
7	CHP	CC-36 SCR-1	LUFFING OLR ACTED	OLR RESET DONE THAN OK	19:35:00	19:50:00	
8	CHP	CC-29 F/G	OLR ACTED	OLR RESET	17:30:00	17:40:00	
9	CHP	CC-29 TT	CC-29 ON CC-111 POSITION INDICATION NOT SHOW IN CCR	SENSOR CABLE REMOVE POSITION RECONNECTED THAN OK	17:40:00	18:00:00	
10	CHP	CC-8 AND CC-9	NOT HEALTHY CHECKED AND FOUND LC-21 IN CM-6 TRIP	CM-6 FEEDER CHARGED THAN OK	21:00:00	21:20:00	
11	CHP	CC-51	OLR ACTED (5TIMES)	OLR RESET DONE (FEEDING CONVEYOR STOPPED)	14:55:00	20:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/09/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-54	OLR ACTED (4TIMES)	RESET DONE	19:05:00	19:30:00	
13	CHP	CC-114	OLR ACTED	OLR RESET DONE	20:00:00	20:10:00	
14	CHP	CC-131	OLR ACTED	RESET DONE	20:35:00	20:40:00	
15	CHP	ALL YARD MACHINE S	SIGNAL MISSING	CHECKED AND FOUND NO PROBLEM	21:30:00	21:45:00	
16	WT	OC-1A	STOPPING ON ZSS CHECKED AND FOUND ZS PROBE AND MADUL PROBLEM	ZS PROBE AND MADUL REPLACED THAN OK	15:00:00	15:45:00	
17	WT	OP-1	NOT MOVE DRIVE -1 OLR ACTED	DRIVE-1 OLR RESET DONE	19:50:00	20:00:00	
18	WT	OP-1	NOT MOVE D-2 MOTOR CABLE GOT CUT	RE-LUGGING AND TAPPING WAS DONE THAN OK	20:15:00	20:35:00	