



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/06/2025

Shift: A

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 19 yard conv.	brs acting/	bypassed at i/o rack for operation request	08:45:00	08:55:00	due to threads
2	OHP	brc on co 33m	It not taking place/drive in manual mode	kept auto mode then ok	07:20:00	07:35:00	
3	OHP	wobr on co 6a	bc not running/	fault reset done then ok	13:50:00	14:00:00	
4	OHP	tbs on co 20	It not taking place/pcrd tension acted	cable winding problem	12:30:00	12:45:00	inform to mech
5	CHP	cc131	tripped on olr	reset done	08:15:00	08:20:00	
6	CHP	cc 54	tripped on olr 3 times	reset done	08:55:00	09:15:00	
7	CHP	cc114	tripped on olr	reset done	11:20:00	11:30:00	
8	CHP	scr 7 on cc39	bc not running/bc c/s acted	reset done	08:30:00	08:40:00	
9	CHP	scr 5 on cc32	It not taking place/mpcb tripped	mpcb made on	08:35:00	08:45:00	
10	CHP	scr 7 on cc39	bw not running/	fault reset done then ok	09:45:00	09:55:00	
11	CHP	cc 201	tripped on olr	reset done	11:00:00	11:10:00	
12	CHP	cc202	tripped on olr	reset done	09:40:00	09:50:00	
13	CHP	scr 8 on cc112	slew not working/30 degree limit acted	reset done	08:50:00	09:00:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/06/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	scr 1 on cc 35	slew not taking place/drive tripped	reset done	11:50:00	12:00:00	
15	CHP	scr4 on cc33	It reverse not taking place/reverse bit not comming	bit bypassed	13:25:00	13:35:00	
16	CHP	scr 4 on cc33	It not taking place/pcrd tension acted duev cable winding problem	reset done	13:35:00	13:45:00	
17	IOSA	wobr old	luffing not taking place/limit acted	reset done	06:30:00	08:10:00	