



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/12/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|------------------------------|----------|----------|---------|
| 1 | OHP | CO-26 | OLR ACTED | RESET DONE | 06:40:00 | 06:45:00 | |
| 2 | OHP | TBS ON CO-20 | REPORTED LT NOT TAKING PLACE PCRD O/T ACTED DUE TO GUIDE PROBLEM | INFORMED TO MECHANICAL | 10:30:00 | 10:40:00 | |
| 3 | OHP | CO-10A | OLR ACTED | RESET DONE | 09:35:00 | 09:40:00 | |
| 4 | CHP | CC-117 | OLR ACTED (5TIMES) | RESET DONE | 07:30:00 | 13:20:00 | |
| 5 | CHP | CC-51 | MPD TRIPPED FEEDING CONVEYOR (14 TIMES) | RESET DONE | 08:00:00 | 13:30:00 | |
| 6 | CHP | CC-54 | TRIPPED ON OLR (8 TIMES) | RESET DONE | 08:40:00 | 13:30:00 | |
| 7 | CHP | CC-203 | REPORTED NOT HEALTHY PULL CHORD ACTED | RELEASED THAN OK | 06:40:00 | 07:20:00 | |
| 8 | CHP | CC-39 SCR-6 | REPORTED B/C NOT RUNNING OLR ACTED | RESET DONE THAN OK | 07:30:00 | 07:40:00 | |
| 9 | CHP | CC-48 | REPORTED BRS ACTED | SENSOR CLEANING DONE THAN OK | 10:10:00 | 10:20:00 | |