



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/10/2025

Area: CHP

Equipment	Job
STK-3	shifted from CC-111 bed to CC-213 bed
SCR-1	Sheet painting under progress
SCR-8	Luff oil level switch fixed and kept in circuit
CC-51 tunnel	CC-51 wall side at cc-112 flap gate point lighting arranged
Misc	RG level screen spare motor coupling fixing done
CC-102	TT PCRD Old joint opened. Jointing done