



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/05/2025

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	15:20:00 19:30:00	15:30:00 19:40:00	
2	OHP	WBR ON CO -26	SLEW NOT WORKING	DRIVE TRIPPED IN OL ... RESET DONE	20:40:00	21:00:00	
3	CHP	CC-28	STOPPING ON ZSS	FC OIL LEAKAGE INFORMED OPERATION	19:45:00	20:00:00	
4	CHP	R-1 CC-31	LT POWER CABLE GOT CUT IN SLEW CHAMBER BECAUSE WRONG DIRECTION SLEW DONE BY OPERATOR	CABLE JOINT DONE	16:20:00	20:50:00	LIMITS TO BE CHECKED IN G SHIFT
5	CHP	CC-31 R-1	SLEW AND LUFF NOT WORKING	POTENTIOMETER WAS IN ZERO ... INCREASED LUFF MATERIAL JAMMING INFORMED FOR CLEANING	14:00:00	14:40:00	
6	CHP	CC-32 SCR-5	LT NOT WORKING	PCRD OVER TENSION RELEASED	14:40:00	14:55:00	
7	CHP	CC-36 SCR-7	SLEW NOT WORKING	MATERIAL JAMMING INFORMED FOR CLEANING	15:30:00	15:40:00	
8	CHP	CC-34 SCR-2	LT NOT WORKING	PCRD OVER TENSION ACTED RELEASED	17:20:00 21:35:00	17:35:00 21:50:00	
9	CHP	CC-40 SCR-6	LT NOT WORKING	DRIVE TRIPPED ON OL ... RESET DONE	17:30:00	17:40:00	
10	CHP	CC-35 S-1	BW NOT WORKING	OLR TRIPPED ... RESET DONE	17:05:00	17:20:00	
11	CHP	CC-112 SCR-8	BW STOPPING ON LOAD	NO ELECTRICAL PROBLEM	17:00:00	18:00:00	