



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment      | Problem  | Action  | From                 | To                   | Remarks           |
|-------|------|----------------|--|---|----------------------|----------------------|-------------------|
| 1     | OHP  | CO 26          | OLR acted  | reset done  | 01:43:00             | 01:53:00             |                   |
| 2     | OHP  | BRC on CO 33M  | BW not rotating                                      | Oil level low, informed to operation  | 02:35:00             | 02:50:00             |                   |
| 3     | OHP  | BRC on CO 34   | BW 2 stopping on zss                                 | Module problem , bypassed in module   | 03:40:00             | 04:00:00             | to be kept in ckt |
| 4     | OHP  | CO 35          | OLR acted  | reset done  | 01:20:00             | 01:25:00             |                   |
| 5     | OHP  | CO 26          | BRS bypass request from operation due to belt hole   | bypassed in module  | 00:30:00             | 00:45:00             |                   |
| 6     | OHP  | TT 1           | Chute vibrator not working                           | MPCB tripped . Meggar done , IR value zero  | 01:30:00             | 02:00:00             | to be changed     |
| 7     | OHP  | VS 4A          | OLR acted  | reset done  | 23:10:00             | 23:20:00             |                   |
| 8     | CHP  | CC 104 , SCR 9 | LT not working due to Overtension acted ( 4 times)   | tension released  | 23:00:00             | 05:00:00             |                   |
| 9     | CHP  | CC 111, R-1    | BC not running due to zss interlock feedback missing | Checked, cage sticking . Cage changed   | 23:35:00             | 00:40:00             |                   |
| 10    | CHP  | CC 32          | Tripped on overload                                  | reset done  | 23:15:00             | 23:35:00             |                   |
| 11    | CHP  | CC 114         | Tripped on overload                                  | reset done  | 02:10:00             | 02:20:00             |                   |
| 12    | CHP  | CC 51          | MPD tripped on overload                              | reset done  | 00:50:00<br>01:15:00 | 00:55:00<br>01:20:00 |                   |
| 13    | CHP  | CC 105, SCR 7  | PCRD chain broken                                    | PCRD drum arrested after mechanical work unsuccessful . Four loop on drum and pcrd power made off | 22:30:00             | 23:45:00             |                   |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 24/07/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

| Sl No | Area | Equipment | Problem              | Action                                | From                             | To                               | Remarks           |
|-------|------|-----------|----------------------|---------------------------------------|----------------------------------|----------------------------------|-------------------|
| 14    | WT   | OT 5      | LS 1 stucked         | bypassed                              | 22:30:00                         | 22:35:00                         | again kept in ckt |
| 15    | WT   | CO 3      | Belt drive OLR acted | reset done                            | 02:25:00<br>03:20:00<br>05:15:00 | 02:35:00<br>03:30:00<br>05:25:00 |                   |
| 16    | IOSA | FLS woblr | BC not running       | Interlock zss cage stucked, made free | 02:25:00                         | 02:40:00                         |                   |