



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/11/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	CT END LIMIT SWITCH REPLACED AND ACTUATOR ADJUSTMENT DONE. CJB and PJB PANELS ARE PROPERLY FIXED. TIGHTNESS CHECKED IN CJB AND PJB.
OC-7A and 7B	LIGHTING AND SWITCH BOARD CONNECTIONS GIVEN FOR BELT JOB
OC-14A	PPM DONE ON MOTOR
OC-13A	PPM DONE ON FIELD DEVICES