



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/05/2025

Area: WT

Equipment	Job
CP 2	panel and motor side ppm done
OP 6	panel and motor side ppm done( Pads to be changed)
OP 1	Col no 75-76, Middle and bottom Bus bars adjusted as per pads position
OP 1,3,4 and 7	after rake maintenance done
SCO 1A	Pull card switch,removed and changed the location ,re fixed and kept in circuit