



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/02/2026

Incharge(s): Amit Roy

Shift: A

| Sl No | Area | Equipment    | Problem                             | Action                                      | From     | To       | Remarks                 |
|-------|------|--------------|-------------------------------------|---|----------|----------|-------------------------|
| 1     | OHP  | TBS on CO-5A | Reported no operations taking place | Control not made on by operator             | 09:10:00 | 09:25:00 | Not an electrical delay |
| 2     | OHP  | CO-76R       | Reported tripped                    | OLR acted.Reset done                        | 10:10:00 | 10:20:00 |                         |
| 3     | OHP  | CO-67        | Reported tripped                    | OLR acted.Reset done                        | 12:50:00 | 13:00:00 |                         |
| 4     | OHP  | BRC on CO-31 | Reported LT not taking place        | PCRD tension acted.Released and tested okay | 13:45:00 | 13:55:00 |                         |
| 5     | CHP  | Cc-51        | MPD tripped                         | Reset done(2 times)                         | 06:40:00 | 11:50:00 |                         |
| 6     | CHP  | CC-117       | Reported tripped                    | OLR acted.Reset done                        | 12:20:00 | 12:25:00 |                         |
| 7     | CHP  | Cc-34 SCR-1  | B/C position gvm side not coming    | Sensor problem.Bypassed and given clearance | 10:30:00 | 10:45:00 | Sensor to be changed    |