



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/05/2025

Area: OHP

| Equipment | Job |
|----------------|---|
| rsco-10a | both cjd's tested and found ok. |
| tis-4 on co-44 | belt is tripping due to metal plate stuck , removed plate and restored for operation. |
| co-5 | pullchord is rectified and kept in circuit. brs is continuing in bypass. |
| brc-34 | ct guide roller structure is damaged, ct limit sw cable towards crmp got cut, rejoined, trail run to be taken after mechanical job. |
| co-3a beltsway | bypassed temporarily for offcentering adjustment, and kept back in circuit after operation clearance. |