



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/10/2025

Area: CHP

Equipment	Job
LC 4	Cleaning done
CM 18	New zss cages welding and fabrication done 15 nos
CC 45 tunnel	2 50w leds kept and improved lighting
CC 202	Lighting circuit problem rectified and improved lighting
R1 on CC 32	Luff down limit tested and kept in circuit
Scr 5	after mech clearance winding done
Scr 5	Lt end limit cable problem rectified kept in circuit
Scr 5 on cc 33	LT motor 4 placed in position