



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/06/2025

Shift: A

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 22	LT not working due to pcrd overtension	tension released	07:35:00	07:45:00	
2	OHP	CO 37A	BRS in bypass condition	Kept in circuit as per operation request	08:20:00	08:27:00	
3	OHP	SB 2A	Bunker level bypass request from operation	bypassed	08:00:00	09:30:00	again kept in circuit
4	OHP	CO 34 BRC	BW 1 stopping on ZSS	Probe replaced, still problem . ZSS bypassed and inform to gen shift	08:45:00	09:20:00	
5	OHP	VS 1A	OLR acted	reset done	11:45:00	11:50:00	
6	OHP	TT 2	Chute vibrator not working due to bearing damaged	Informed to gen shift	13:00:00	13:10:00	
7	OHP	RSCO 1A	Carriage drive tripped on overload	reset done	07:50:00	08:00:00	
8	OHP	CO 31 BRC	LT not working	Drive tripping on earth fault. M-5 disconnected and speed reduced . Informed to gen shift	06:15:00	07:00:00	
9	CHP	CC 32	OLR acted	reset done	07:20:00	07:30:00	
10	CHP	CC 32 , SCR 5	BC not running	OLR acted , reset done	07:25:00	07:30:00	
11	CHP	CC 32 , SCR 5	LT not working	M-2 , M-3 tripped . Reset	11:45:00	12:10:00	
12	CHP	CC 105 , SCR 10	BC not running in Rec mode	ZSS interlock checked, but due to coal stucked not working. Then material selection bypassed for CC 105	08:00:00	09:00:00	
13	CHP	CC 112 , SCR 8	BC not healthy	chute jamming , informed to operation	08:15:00	08:30:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 34 , SCR 2	Luff not working	Found oil leakage is there, informed to mechanical	08:30:00	09:00:00	
15	CHP	CC 31 , R -1	LT not working	Found that track jamming , informed to operation	08:30:00	08:50:00	
16	CHP	CC 54	OLR acted	reset done	09:45:00	09:50:00	
17	CHP	CC 117	OLR acted	reset done	10:20:00	10:30:00	
18	CHP	CC 131	OLR acted ( 2 times)	reset done	12:45:00	13:05:00	
19	CHP	CC 114	BRS bypass request by operation	bypassed	09:25:00	09:40:00	
20	WT	OC 1A	Pull chord not healthy	Bypassed and informed to gen shift	09:00:00	09:40:00	