



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/01/2026

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-34	Reported tripped	OLR acted.Reset done(2 times)	23:50:00	03:00:00	
2	OHP	CO-26	Reported tripped	OLR acted.Reset done	02:45:00	02:55:00	
3	CHP	CC-216	Reported tripped	OLR acted.Reset done	05:30:00	05:40:00	
4	CHP	CC-216	CJD acted	Due to coal and moisture mixture.Probe cleaned and tested okay	00:35:00	00:50:00	
5	CHP	CC-125	Reported tripped	OLR acted.Reset done	04:55:00	05:05:00	
6	CHP	Cc-131	Reported tripped	OLR acted.Reset done	01:55:00	02:00:00	
7	WT	AF-5	Reported tripped	Drive-1 tripped due to overcurrent for jamming(3 times)	01:45:00 02:00:00 02:15:00	01:50:00 02:05:00 02:20:00	
8	WT	OT-4	Reported tripped	Drive-1 tripped due to PGEF-1 tripped.	01:50:00	01:55:00	
9	WT	AF-3(CT-2)	Reported not running in local	E-stop PB acted.Released and tested okay	00:05:00	00:20:00	
10	WT	CP-1	Reported tripped while doing reverse	Breaker tripped in LC during movement at column(16-23). Kept in local and pusher kept at parking zone	22:30:00	23:00:00	