



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 15/09/2025

Area: CHP

| Equipment               | Job  |
|-------------------------|--|
| CC 113 BSS              | Two ckts earth fault isolated and made through     |
| CC 113 LDB              | RECTIFICATION DONE AND IMPROVED LIGHTING           |
| LC 18,CM 19             | Transformer room and panel room cleaning done      |
| CC 222/223              | Belt scale systems maintenance was done            |
| CC 31 SCR 4             | ZSS and Boom position kept in ckt                  |
| JH C 210,211,CC 215 T/E | Pumps auto mode tested , rectified and trial taken |
| CC 37 HT coupler        | Clamp fixed, cable taping done                     |
| CC 33,111,R1,S3         | PPM was done                                       |