



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR ON CO 29	LT NOT TAKING PLACE M4 MPCB TRIP	RESET	08:45:00	09:00:00	
2	OHP	TT 2 ON CO 22	POSITION INDICATION PROBLEM CABLE GOT CUT	JOINT DONE THAN OK	09:15:00	09:35:00	
3	OHP	TBS ON CO 22	LT NOT TAKING PLACE DRIVE TRIP	RESET	09:15:00	09:30:00	
4	OHP	BRC ON CO 8A	B/W 1 OLR TRIP	RESET DONE	11:30:00	11:45:00	
5	OHP	VF 21	NOT HEALTHY MCCB AUX BLOCK PROBLEM	RECTIFIED	12:45:00	13:00:00	
6	OHP	CO 30 BRC	B/W NOT RUNNING, ZSS FAULT	FAULT RESET	12:50:00	13:10:00	
7	CHP	CC 131	OLR ACTED	RESET	10:35:00	10:45:00	
8	CHP	CC 117	OLR ACTED	RESET	11:35:00	11:45:00	
9	CHP	CC 51A	B/S ACTED	BELT OFF CENTRING ADJUSTED BY MECH THEN OK	11:45:00	12:00:00	
10	CHP	CC 36 SCR 1	GVM SIDE POSITION INDICATION NOT SHOWING	BYPASS IN I/O RACK	06:30:00	06:35:00	
11	CHP	CC 112 SCR 8	LUFF NOT WORKING CONTROL MCB TRIP	MADE ON AND LOWER LIMIT BY PASS	06:45:00	07:00:00	
12	CHP	CC 38 SCR 3	LT NOT TAKING PLACE O/T ACTED	RELEASED	07:50:00	08:00:00	
13	CHP	CC39 SCR 7	LT NOT TAKING PLACE O/T ACTED	RELEASED	10:20:00	10:30:00	