



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/01/2026

Area: CHP

Equipment	Job
CC 107/108 tunnel	5 nos 30W lamps replaced
CC 114	4 nos lamp fixtures replaced
LC 17,CM 19	IO rack prophie bus cable loopings replaced with new ones
SCR 7,S2,SCR 2,6	Machine to yard focusing lamp fixtures replaced
SCR 3	LT panel door fixed
All Hoists	Total CHP JH Hoists inspected with external agency
CC 107,205,206,207,208,209,210,211	PPM was done