



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 25/09/2025

Area: CHP

Equipment	Job
CC 13,17,24	PPM was done
Coal complex	Rooms cleaning done
SCR 9	Yard ZSS interlock kept in ckt after doing necessary programming and tested
CC 31,38,40,48	Motor Vibration values noted
CC 201,222,223 belt scale	Maintenance was done
CC 45/46	2 nos 50W lamps replaced
Street lights	Cable problems rectified and improved little lighting. Lamp fixtures to be replaced
CC 34,41,SCR 2	PPM was done