



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/06/2025

Area: WT

Equipment	Job
OP 6	All over load relays checked ,dash pot oil replaced in D1 and 3
OP 6	Main contactor ( vacuum) R- phase bottle found defective replaced it
OP 6	All motors checked ,found D3 stator cable lug cut in TB,replaced
OT 4	Hydraulic pump 1 motor removed and coupling also removed
OP 1	D2 motor removed due to motor burnt
OP 2,3 and 5	after rake maintenance done
CP 1 and 3	after rake maintenance done