



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 25/09/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 15	OLR ACTED	RESET	04:00:00	04:05:00	
2	OHP	BRC ON CO 32	OLR ACTED C/S BYPASSED	RESET	02:00:00	02:10:00	C/S ACTING FREQUENTLY PROBE LENGTH HAS TO BE ADJUSTED
3	OHP	CO 29	OLR ACTED	RESET	23:50:00	00:00:00	
4	OHP	BRC ON CO 32	O/T ACTED DUE TO CABLE ZIGZAG	RELEASED AND INFORMED MECH TO GUIDE ADJUSTMENT	05:40:00	06:00:00	
5	OHP	VS 1A	OLR ACTED	RESET	03:40:00	03:50:00	
6	OHP	RSCO 6A CARRIAGE DRIVE	OLR ACTED	RESET	01:40:00	01:55:00	
7	OHP	CO 10A	OLR ACTED	RESET	04:50:00	05:00:00	
8	OHP	CO 49	OLR ACTED	RESET	05:20:00	05:30:00	
9	CHP	scr7 ON CC 37	LT O/T ACTED	RELEASED	23:05:00	23:25:00	
10	CHP	SCR 4 ON CC 31	CHARGE PRESSURE ACTED	RESET	01:35:00	01:55:00	
11	CHP	SCR 2 ON CC 34	LT O/T ACTED	RELEASED	23:55:00	00:15:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/09/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	SCR 3 ON CC 40 B/C	OLR ACTED	RESET	01:45:00	02:00:00	
13	CHP	R1 ON CC 33	SLEW DRIVE TRIPPED	RESET	04:45:00	05:00:00	
14	CHP	CC 202	BSS ACTED	BY PASSED	04:20:00	05:00:00	C/S BYPASS LOOP LOOSE TIG HTENED
15	CHP	SCR 1 ON CC 36	LUFF OIL LEAKAGE	INFORMED TO MECH	05:20:00	05:40:00	
16	CHP	CC 58 T/T POSITION	SENSOR BYPASS LOOP LOOSE	TIGHTENED	02:30:00	02:45:00	
17	CHP	CC51	FEEDING CONV OLR ACTED	RESET	23:30:00	06:00:00	7 TIMES
18	CHP	CC 31 F/G	OLR ACTED	RESET	01:00:00 23:00:00	01:10:00 23:10:00	
19	CHP	CC 28	OLR ACTED	RESET	04:50:00	05:00:00	
20	WT	OT2	D2 DRIVE TRIPPED ON PGF1	RESET	03:40:00	03:45:00	