



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/05/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC 28	B/w 2 not moving, olr acted	reset it done	19:15:00	19:30:00	
2	OHP	CO 25	olr acted	reset it done	16:00:00	16:10:00	
3	OHP	Co 78	not healthy,e stop	emergency released	19:45:00	19:55:00	
4	OHP	wobr 26	no lighting complaint,lighting mcb is in off	made it on	18:20:00	18:30:00	
5	CHP	CC 36	ZSS not healthy,sensor cable loose connection	cable tightened	15:20:00	15:30:00	
6	CHP	CC 54	OLr acted	reset it done	18:30:00	18:35:00	
7	CHP	CC 117	olr acted	reset it done	20:50:00	21:00:00	
8	WT	co 3 (c)	mpcb trip due to jamming	made it on	20:00:00	20:10:00	