



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 05/08/2025

Area: OHP

Equipment	Job
CO 63, CO 60	MOTOR AND PANEL PPM DONE
37 KW MOTOR	SHIFTED FROM JH-C18 TO LC7
LC3	UNWANTED CABLE REMOVAL UNDER PROCESS
BRC3 ON REPAIR BAY	MCC ALL DRIVES CLEANING DONE, REPAIR BAY WELDING MACHINE MCCB HANDLE REPLACED
BRC ON CO 34 ANALOG I/P	CABLE REPLACED AND RTD KEPT IN CIRCUIT
CO 9A	EMERGENCY PB STATION REPLACED
CO 10-A HEAD END	200W LIGHT FIXED
RSCO 1A	200W LIGHT FIXED
CO 8, 11 , 14 M	OTOR SIDE AND PANEL SIDE PPM DONE
ALL TTS	WIRELESS SYSTEMS ANTEENA, SATELL MODEMS SHIFTED TO LC7
TT	NEW WIRELESS SYSTEMS SHIFTED TO LC3
CC 24	POWER CABLE JOINT DRESSING DONE
CHP AREA	ALL FIELD DEVICES INSPECTION DONE