



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/06/2025

Area: IOSA

Equipment	Job
FILED DEVICES	OC-19A, OC-23A, OC-25A, OC-29A, OC-31A, OC-33A, OC-37A FIELD DEVICES FEEDBACK CHECKED.
WOBR-FLS	PPM DONE ON PANEL , HYD.MOTORS, PCRD MOTOR AND CONTROL DESK.
OC-27A	PPM DONE ON MOTOR. IR VALUES CHECKED AND RECORDED.
OC-19A	PPM DONE PANELS AND MOTORS OF DE-WATERING SYSTEM