



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/08/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: C

| Sl No | Area | Equipment          | Problem                                | Action   | From                 | To                   | Remarks                |
|-------|------|--------------------|--|--|----------------------|----------------------|------------------------|
| 1     | OHP  | CO-18 TO CO-23 F/G | NOT MOVE OLR ACTED                     | RESET DONE   | 23:00:00             | 23:10:00             |                        |
| 2     | OHP  | CO-26              | REPORTED RED OLR ACTED                 | RESET DONE   | 01:30:00<br>02:55:00 | 01:40:00<br>03:10:00 |                        |
| 3     | OHP  | TBS ON CO-23       | LT NOT TAKING PLACE CHECKED DRIVE TRIP | RESET DONE   | 02:20:00             | 02:40:00             |                        |
| 4     | OHP  | CO-87              | NOT RUNNING CHECKED OLR ACTED          | RESET DONE   | 03:40:00             | 03:50:00             |                        |
| 5     | OHP  | BRC ON CO-31       | Reported B/W-1 moving slowly           | Checked and electrically found okay. Mechanical side to be checked | 02:30:00             | 04:00:00             | Informed to mechanical |
| 6     | CHP  | CC-54              | Reported not healthy                   | OLR acted. Reset done(2Times)                                      | 00:50:00<br>01:00:00 | 00:55:00<br>01:05:00 |                        |
| 7     | CHP  | CC-51              | Reported not healthy                   | OLR acted. Reset done  | 05:20:00             | 05:25:00             |                        |
| 8     | CHP  | CC-34              | Reported not healthy                   | OLR acted. Reset done  | 22:20:00             | 22:30:00             |                        |
| 9     | CHP  | CC-125             | Reported not healthy                   | OLR acted. Reset done  | 23:40:00             | 23:45:00             |                        |
| 10    | CHP  | CO-44              | Reported not healthy                   | OLR acted. Reset done  | 02:55:00             | 03:05:00             |                        |
| 11    | WT   | OT-2               | NOT MOVING CHECK DRIVE-1 TRIP          | RESET DONE   | 02:30:00             | 02:35:00             |                        |