



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/02/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 5A,6A,OM 28,wobr on co 26	no power	power restoration done	04:20:00	04:45:00	
2	OHP	wobr on co 26	yard conveyor zss interlock,control off	control made on	23:50:00	00:00:00	
3	OHP	CO 26	olr acted	reset	03:30:00	03:39:00	
4	CHP	cc 51	mpd acted 3 times	reset	03:40:00	03:45:00	
5	CHP	CC 31	olr acted	reset	22:05:00	22:10:00	
6	CHP	CC 203	olr acted	reset	22:55:00	23:00:00	
7	CHP	CC 39 SCR6	slew not working,jamming	informed operation	01:20:00	01:30:00	
8	CHP	CC 203	pc acted	released	01:45:00	02:00:00	
9	CHP	CC112,CC 105,CC111	no power	individual breaker made on	04:15:00	05:00:00	
10	CHP	CC 31 SCR 4,CC 40 SCR2	no power	power recycle done	04:15:00	05:00:00	
11	IOSA	brc	b/w no movement ,full jamming	informed operation	01:30:00	01:45:00	
12	IOSA	all conveyor	no power	power restoration done	04:10:00	04:40:00	