



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 15/01/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|--|--|----------|----------|---------|
| 1 | OHP | CO-16 | TRIPPED ON OLR | RESET DONE | 16:00:00 | 16:10:00 | |
| 2 | OHP | WBR ON CO 25 | LT NOT MOVING .. PCRD TENSION ACTED | RELEASED | 15:35:00 | 15:45:00 | |
| 3 | OHP | CO-25 WBR | LT M2 TRIPPED | RESET DONE AND BREAK ADJUSTED BY MECH | 16:00:00 | 16:20:00 | |
| 4 | OHP | CO-26 | TRIPPED ON OLR | RESET DONE | 16:45:00 | 16:55:00 | |
| 5 | OHP | CO-33M BRC | BC NOT RUNNING ... CHUT SENSOR PROBLEM | BYPASS..ON INSTRUMENTATION AND OPR REQUEST | 17:05:00 | 17:20:00 | |
| 6 | OHP | CO-67 | TRIPPED ON OLR | RESET DONE | 20:35:00 | 20:40:00 | |
| 7 | CHP | CC-103 TT | 103 TO 105 TT POSITION NOT COMING | LOOSE IN IO RACK ... FIXED | 20:00:00 | 20:20:00 | |
| 8 | CHP | CC-51 | TRIPPED ON MPR 6 TIMES | RESET DONE | 16:50:00 | 21:40:00 | |
| 9 | CHP | CC-131 | TRIPPED ON OLR 4 TIMES | RESET DONE | 17:30:00 | 21:30:00 | |
| 10 | CHP | CC-51A | ZSS CAGE STONE STUCK | REMOVED | 16:20:00 | 16:30:00 | |
| 11 | WT | op-2 | D5 TRIPPED | REST DONE | 21:45:00 | 21:55:00 | |