



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/02/2026

Area: CHP

Equipment	Job
JH 209	Sump pump replaced and kept in auto
CC 35,36,38,106,222,SCR 3,4,6,S 1	Running inspection was done
SCR 9	Luff UP limit adjusted as per operation requirement
CC 213	Drive end chute sensor modified with Liner sheet
CC 215,217,220,106	PPM WAS DONE