



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/07/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	OLR ACTED	OLR RESET	06:45:00	06:55:00	
2	OHP	CO 35	OLR ACTED	RESET	08:00:00	08:10:00	
3	OHP	BRC ON CO-33M	HYDRALIC PUMP NOT RUNNING OIL LOW LEVEL	INFORMED TO OPERATION	07:15:00	07:30:00	
4	OHP	BRC ON CO-34	ALL DRIVES ARE NOT RUNNING CHECKED ACB TRIP	ACB MADE ON THAN OK	08:04:00	09:00:00	
5	OHP	CO 87	REPORTED RED CHECKED PULL CHORD ACTED	INFORMED TO OPERATION	11:40:00	11:50:00	
6	OHP	CO-14	B/S ACTED CHECKED CABLE GOT CUT	B/S BYPASSED IN CJB.Cable joint done and kept in circuit	11:30:00	11:45:00	CABLE COVER WITH MATERIAL HUMP
7	OHP	CO-42A	REPORTED BRS NOT RESET	BRS SENSORS CLEAN THAN OK	11:30:00	11:45:00	
8	OHP	CO 5	REPORTED E/STOP NOT RELEASED CHECKED WIRE OPEN CONDITION IN PB POST	E/STOP WIRE CONNECTED THAN OK	12:00:00	12:10:00	
9	OHP	CO 14B	OLR ACTED	RESET	12:35:00	12:45:00	
10	OHP	BRC ON CO 30	CT NOT TAKING PLACE DRIVE TRIP	RESET	12:30:00	12:50:00	
11	OHP	CR-1A	Stopping on ZSS fault	Jamming found.ZSS probe covered with material.	12:30:00	12:45:00	informed to operation



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/07/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	OHP	RSCO-1A(C/D)	Reported not moving	OLR acted.reset done	13:40:00	13:50:00	
13	OHP	DB-1	Reported C/S acted	High in C/S module found in removed condition.Reconnected and tested okay	13:30:00	13:45:00	
14	CHP	CC-18	OLR ACTED	RESET	07:30:00	07:40:00	
15	CHP	CC-117	OLR ACTED (2TIMES)	RESET	10:30:00 11:30:00	10:40:00 11:40:00	
16	CHP	CC 54	OLR ACTED (3TIMES)	RESET	07:05:00	07:10:00	0840,08-50
17	CHP	CC-52	OLR ACTED	RESET	10:10:00	10:20:00	
18	CHP	CC-28 TT	POSITION INDICATION NOT SHOWING OON CC-33 GLASS FUSE BLOWN IN I/O RACK	FUSE REPLACED THAN OK	12:40:00	12:50:00	
19	CHP	cc-38 s-1	Slew not taking place	checked and found jamming.after clearing jamming tested okay	06:50:00	07:15:00	informed to operation
20	CHP	CC-105 SCR-7	slew not taking place	Wrong complaint	07:20:00	07:30:00	informed to operation
21	CHP	CC-34 SCR-2	B/C not starting in reclaiming mode	checked and found to be working fine	08:35:00	09:50:00	Wrong complaint
22	CHP	CC-40 SCR-3	Reported LT not taking place	PCRD olr acted. reset done	09:35:00	09:45:00	
23	CHP	CC-201	Reported not healthy	PC acted.Released and tested okay	10:30:00	10:50:00	
24	CHP	CC-203	Reported not healthy	olr acted. reset done	11:04:00	11:13:00	
25	CHP	CC-31 S-3	Reported B/C not working	OLR acted.reset done	11:50:00	12:10:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/07/2025

Shift: A

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
26	CHP	CC-105 scr-10	Reported signal missing	LT forward done and tested okay	12:40:00	12:50:00	
27	CHP	CC-125	Reported not healthy	OLR acted. reset done	13:20:00	13:25:00	