



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/01/2026

Incharge(s): G Eswara Rao

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------------------|----------------------|------------------|
| 1 | OHP | wobr on co 26 | BC not running. olr acted | reset done | 12:40:00 | 13:00:00 | |
| 2 | CHP | cc 56 | reported c/s not working. | c/s kept wrong position while cleaning chute. kept correct position. | 10:30:00 | 10:50:00 | |
| 3 | CHP | cc 12 | brs not getting reset/sensors alignment distrub | sensors adjusted then ok | 11:30:00 11:50:00 | 11:45:00 12:00:00 | |
| 4 | CHP | cc 131 | tripped on olr 2 times | reset done | 07:30:00 10:30:00 | 07:40:00 10:40:00 | |
| 5 | CHP | cc 112 | tripped on olr2times | reset done | 09:50:00 | 10:00:00 | |
| 6 | IOSA | tbs on oc 13a | It not taking place/m4 olr acted | reset done | 12:20:00 | 12:45:00 | gear box problem |