



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/05/2025

Area: OHP

Equipment	Job
tt-2 on co-21	posiiton bit is byapssed at io rack , suspecting postion cable to cjb got cut, and cable is under heavy spillage material, informed operation to clear the spillage.