



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/10/2025

Area: WT

Equipment	Job
EOT COAL TIPPLER	FWD POWER CONTACTOR DAMAGE TWO TIPS CHANGE, R-PHASE LUGGING DONE
CO-3	CARRIAGE MOTOR TB FIXED PROPERLY
OP-1,4,6,8 CP-2,3,4	PUSHER INSPECTION DONE AT PARKING ZONE.