



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/11/2025

Area: OHP

| Equipment | Job |
|--|---|
| tbs- on repair bay | rbc motor termination is done and zss cable is laid., |
| brc 5 on co-32 | festoon cable cleaned and maintenance is done ; bridge conveyor motor earth jumper is provided. |
| tbs-2 on oc-22 | pcrd resistance box cleaned; |
| co-86 head end ; 77,78 gallery | illumination is improved |
| co-77,84,86 and their hoists | motor and panel side ppm is done |
| co-13a, 42a ,14b,16a ,11a,vs-1a level gallery, ; | illumination is improved |
| daybins-2 ; 11a,12a, cbms- on co-11a hoists | hoists ppm is done |
| reclaiming streams | cjd's ppm is done |