



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/05/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 87	reported fail to start/power contractor arc chute cover not fixed properly	fixed properly then ok	18:45:00	19:10:00	
2	OHP	co 35	tripped on olr	reset done 2 times	20:10:00 20:50:00	20:20:00 21:00:00	
3	OHP	brc on co 33m	bw 1 not running/olr acted	reset done	19:00:00	19:20:00	
4	CHP	cc 36	brs acting due to dust/sensors cleaning done	reset	16:15:00	16:30:00	
5	CHP	cc54	tripped on olr	reset done	17:20:00	17:30:00	
6	CHP	cc 131	tripped on olr	reset done	17:30:00	17:35:00	
7	CHP	scr 4 on cc 36	It not taking place	under tension limit acted/reset done	20:55:00	21:00:00	
8	CHP	s1 on cc35	It not taking place/pcrd cable drum not rotating	mech.gear box problem .informed to mech. and operation	18:00:00	18:30:00	