



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-4 ON CO 7A	POSITON INDICATION PROBLEM CHECKED SENSOR DAMAGED	DIRECTLY CONNECTED YHAN OK	03:45:00	03:55:00	
2	OHP	WOBR ON CO-26	Slew not taking place	Drive tripped.Reset done	02:00:00	03:10:00	
3	OHP	BRC on CO-31	B/C not running	Interlock ZSS cage stuck up with stone.Stone removed and tested okay	04:00:00	04:10:00	
4	OHP	BRC on CO-28	B/W-1 not running	OLR acted.(2 times).Reset done	04:40:00	05:30:00	
5	OHP	BRC on CO-34	Reported B/W's not running	Checked and found low oil temperature alarm. HMI showing 0.Temperature bypass done and tested okay	05:15:00	05:30:00	informed to instrumentation
6	CHP	cc-201	olr acted	olr reset	23:10:00	23:20:00	
7	CHP	CC-125	OLR ACTED	RESET	04:30:00	04:35:00	
8	CHP	CC-33 SCR-4	SLEW AND LUFF NOT WORKING	CHECKED NO ELECTRICAL PROBLEM TRAIL RUN TAKEN THAN OK	23:45:00	00:00:00	
9	CHP	CC 114	Reported not healthy	olr acted.Reset done(2times)	01:05:00 23:30:00	01:10:00 23:40:00	
10	CHP	CC-54	Reported not healthy	OLR acted(3times).Reset done	01:45:00 02:00:00 03:30:00	01:50:00 02:05:00 03:40:00	
11	CHP	CC-52	Reported not healthy	OLR acted.reset done	05:25:00	05:30:00	
12	WT	OT-4	DRIVE 1 TRIP (PGF)FAULT (2TIMES)	DRIVE RESET	00:45:00	01:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/08/2025

Shift: C

Incharge(s): Amit Roy, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	CC-2(B/D)	OLR ACTED (3TIMES)	RESET	01:40:00	02:15:00	DUE TO MATERIAL JAMMING
14	WT	OP-1	NOT RUNNING D6 OLR ACTED	RESET THAN OK	03:50:00	04:00:00	