



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-12	REPORTED NOT HEALTHY FOUND POWER MCCB AUX CONTACT PROBLEM	AUX BLOCK PROPERLY FIXED THAN OK	08:10:00	08:20:00	
2	OHP	TBS ON CO-5A	REPORTED LT NOT TAKING PLACE FOUND CONTROL MCB OFF CONDITION	MCB MADE ON THAN OK	10:30:00	10:40:00	
3	OHP	BRC ON CO-31	B/W-1 OLR ACTED	RESET DONE	10:50:00	11:00:00	
4	CHP	CC-51	TRIPPED ON MPD (10 TIMES) FEEDING CONVEYOR STOP	RESET DONE	07:00:00	13:20:00	
5	CHP	CC-51	TRIPPED ON OLR	RESET DONE	13:00:00	13:10:00	
6	CHP	CC-55	REPORTED NOT HEALTHY FOUND P/C ACTED	PULL CHORD BYPASSED THAN OK	11:00:00	11:20:00	
7	CHP	CC-103	REPORTED BRS NOT HEALTHY	BRS SUPPLY RE-CYCLED THAN OK	06:40:00	06:50:00	
8	CHP	TT ON CC-102	REPORTED C/S NOT HEALTHY LOOSE AT I/O RACK	TIGHTENED THAN OK	11:20:00	11:40:00	
9	CHP	CC-29	TRIPPED ON OLR	RESET DONE	13:40:00	13:50:00	
10	CHP	CC-47	DRIVE TRIP	RESET DONE	07:30:00	07:40:00	
11	CHP	CC-35 SCR-3	B/C TRIP ON OLR	RESET DONE	08:10:00	08:20:00	
12	CHP	CC-213	OLR ACTED	RESET DONE	08:30:00	08:40:00	
13	CHP	CC-45	OLR ACTED(2TIMES)	RESET DONE	11:25:00 11:55:00	11:30:00 12:00:00	
14	WT	AF-4	DRIVE TRIP FAULT CODE SPEED VARIATION	RESET DONE THAN OK	07:00:00	07:10:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/01/2026

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OT-2	DRIVE-2 PGF-1 FAULT TRIP (7TIMES)	RESET DONE	06:30:00	13:25:00	
16	WT	OP-5	WAGON SENSOR ACTED FREQUENTLY	DISCONNECTED THAN OK	10:15:00	10:40:00	
17	IOSA	TBS ON OC-13A	COMMUNICATION PROBLEM	PLC POWER RE-CYCLED THAN OK	07:20:00	07:40:00	