



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 08/10/2025

Area: CHP

Equipment	Job
Misc	JH-7 and tunnel lighting improvement done
CC-55	ppm done
STK-3	shifted from CC-111 bed to repair bay for slew drive modification
SCR-5	LT drive replaced, parameters, control wiring checked and made ok. Failed drive shifted to CM-18
CC-45,48,49	ppm done
CC-108,125,219,222,105,SCR-10	Running inspection done