



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO34	LT not working found skewing CRMP side acted and found track jamming on CRIMP side and brake problem	Informed to operation jamming some what cleared and mechanical brake adjusted and LT FWD and REV done ok	18:00:00 18:30:00	18:15:00 19:00:00	E- PB struck at cabin side is to be replaced in G shift( Not an electrical problem)
2	OHP	CO26	olr acted	Reset done	17:20:00	17:30:00	
3	OHP	CO35	olr acted	Reset done	17:25:00 17:45:00 20:00:00	17:30:00 17:50:00 20:10:00	
4	OHP	CO58 belt	MPCB trip	Reset done	21:05:00	21:15:00	
5	OHP	CO29	olr	reset done	19:00:00 21:30:00	19:20:00 21:34:00	
6	OHP	CO58	MPCB trip	Reset done	20:00:00	20:15:00	
7	CHP	CC32	olr acted	Reset done	14:50:00	15:05:00	
8	CHP	CC43	olr acted	Reset done	15:15:00	15:25:00	
9	CHP	CC31	olr acted	reset done	15:30:00	15:45:00	
10	CHP	CC13	After mechanical clearance motor termination done	trail taken found ok	20:00:00	20:15:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 31/08/2025

Incharge(s): V Balaji Naik, Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
11	CHP	CC51	MPD tripped on olr and feeding conveyor stopped 4 times.	reset done	18:30:00	18:35:00	06.40pm to 06.45pm:07.05pm to 07.10pm:07.20pm to 07.25pm
12	CHP	CC54	olr acted	reset done	14:10:00	14:15:00	
13	IOSA	L and T WOBR	B/W PUMP NOT GETTING ON, found ball valve LS7 valve not healthy	get released	18:45:00	19:45:00	
14	IOSA	L and T WOBR	b/c not running, olr acted	olr reset	19:55:00	20:10:00	