



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tt1 on co 7a	chute position signal not coming to ocr/control wire connectors came outnear chute.	connectors fixed and re-connected then ok	11:55:00	12:10:00	
2	OHP	tt 4 on co 3a	It not taking place/pcrd cable got earth at old joint due to insulation damaged	insulation done then tested ok	11:20:00	11:45:00	
3	OHP	co 29	tripped on olr 3times	reset done	06:40:00 08:50:00	06:45:00 09:00:00	
4	OHP	co 33m	tripped on olr	reset done	07:30:00	07:35:00	
5	OHP	tbs on co 21	It not taking place/m4 olr acted	reset done	06:30:00	06:45:00	
6	OHP	tbs on co 7a	It not taking place/m 3 olr acted due to y phase got open.	olr replaced tested ok	11:00:00	11:30:00	
7	CHP	scr 9 on cc104	It not taking place/pcrd tension acted	tension released	07:25:00	07:35:00	
8	CHP	scr 8 on cc112	bc not running/olr acted due over material	resetvdone	07:45:00	07:55:00	
9	CHP	cc 39	tripped olr	reset done	08:20:00 11:35:00	08:25:00 11:45:00	
10	CHP	cc 45	tripped on olr	reset done	09:30:00	09:35:00	
11	CHP	cc 125	tripped on olr	reset done	09:40:00	09:45:00	
12	CHP	scr 4 on cc34	It not taking place/pcrd tension acted	tension released	09:40:00	09:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 21/07/2025

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	cc 29	zss acting /motor taking high current due to rat inside the fused isolator	module racked out and cleaning done then rack in the module then tested ok	11:45:00	11:55:00	cc 31,32,33, 111 112 brs acted due to power off for cc 29
14	CHP	scr 5 on cc32	It not taking place/drive trip olr	reset done	12:20:00	12:30:00	