



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 113	OLR acted	reset done	22:20:00 22:30:00	22:25:00 22:40:00	
2	OHP	CO 29	OLR acted	reset done	02:40:00	02:45:00	
3	OHP	CO 51	ZSS acting bcz of belt loose	Informed to mechanical	01:00:00	01:15:00	
4	OHP	TBS on CO 21	LT not taking place	M1 , M3 overload acted , reset done	23:40:00	00:00:00	
5	OHP	WOBR on CO 29	LT not working	M4 overload acted, reset done	03:45:00	04:00:00	
6	OHP	BRC on CO 33M	Hydraulic pump not starting	oil level low. informed to operation	02:30:00	02:45:00	
7	OHP	CO 6A	BRS bypass request by operation due to belt pieces	bypass done	04:20:00	04:30:00	
8	OHP	CO 76R	OLR acted	reset done	03:00:00	03:10:00	
9	OHP	CO 64	OLR acted	reset done	00:30:00	00:40:00	
10	OHP	CO 63	OLR acted	reset done	03:00:00	03:10:00	
11	OHP	CO 76R	Chute sensor malfunctioning	checked, found okay	04:00:00	04:30:00	
12	CHP	CC 51	Tripped on overload	reset done	01:50:00	01:55:00	
13	CHP	CC 34 , SCR2	LT not working due to OT acted	released , then ok	23:50:00	00:00:00	
14	CHP	CC 104 , SCR 9	BC not running due to chute sensor acted	chute jamming is there, informed operation	03:05:00	03:20:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 27/07/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC 36 , S 2	PCRD cable fell down	PCRD panel main contactor R phase damaged . Temporary packing done	23:20:00	01:00:00	Need to be changed