



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/12/2025

Shift: A

Incharge(s): Lal Singh,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CC-33M	OLR ACTED	RESET DONE	07:50:00	07:55:00	
2	OHP	CO-25	TRIPPED ON OLR	RESET DONE	08:45:00	08:55:00	
3	OHP	WBR ON CO-26	SLEW DRIVE TRIPPED	RESET DONE	08:45:00	09:00:00	
4	OHP	WBR ON CO 25	ZSS INTERLOCK CAGE STUCK	RELEASED	09:15:00	09:30:00	
5	OHP	CO-26	TRIPPED ON OLR	RESET DONE	09:45:00 12:00:00	09:55:00 12:10:00	
6	OHP	CO-33M BRC	LT NOT WORKING PCRD PROBLEM	LOOP GIVEN .. MACHINE GIVEN IN RUNNING	13:15:00	13:45:00	PCRD OLR AND MCB TO BE CHANGED
7	CHP	CC-201	TRIPPED ON OLR	RESET DONE	06:40:00	06:50:00	
8	CHP	CC-203	TRIPPED ON OLR	RESET DONE	06:40:00	06:50:00	
9	CHP	CC-31 scr-4	BC STOPPING ON ZSS ... PROB PROBLEM	BYPASSED AND GIVEN FOR STACKING	08:55:00	09:10:00	
10	CHP	CC-47	STOPPING ON ZSS... BECOUSE OF OVER LOAD	INFORMED OPERATION	11:05:00	11:15:00	
11	CHP	CC 113	OLR ACTED	RESET	07:02:00	07:08:00	
12	CHP	CC 117	olr acted	reset	07:55:00	07:59:00	2 times
13	CHP	CC 54	olr acted	reset	10:38:00	13:30:00	11 times
14	CHP	cc-38 S-1	PCRD GUIDE PROBLEM	INFORMED MECH	12:00:00	12:15:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 23/12/2025

Shift: A

Incharge(s): Lal Singh,Lal Singh

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-34 SCR-1	PCRD CABLE FALLEN	WINDING DONE	13:15:00	13:25:00	
16	WT	CO-4	TRIPPED ON OLR	RESET DONE	07:00:00	07:20:00	
17	IOSA	HVMCC-6	IC-1 TRIPPED	POWER RESTORED	08:10:00	08:30:00	