



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO49	not healthy olr acted due to jamming	reset	07:00:00	07:30:00	
2	OHP	co 10A	not healthy, olr acted	reset	07:20:00	07:25:00	
3	OHP	VS 2	olr acted, due to jamming	reset	08:30:00	08:45:00	
4	OHP	BRC on CO 32	LT not taking place ,OT acted,PCRD guide problem	OT released,informed operation for guide adjustment no one came	08:40:00	08:55:00	
5	OHP	BRC on Co32	B/C stop,OLR acted	reset	09:30:00	09:34:00	
6	OHP	RSCO10(A)	not healthy cjd acted yard side,	checked at site chute sensor healthy and working fine ,in I/O rack bit not coming,may be core problem,Thejo person deny to bypass in I/O rack,I bypassed in I/o rack XA05-7	13:15:00	13:40:00	
7	CHP	CC 38 SCR6	slew not working,limit acted	informed operation,released	07:20:00	07:30:00	
8	CHP	CC 108	olr acted	reset	13:18:00	13:21:00	
9	CHP	CC 42	not healthy,brs acted,	BRS bypassed,BRS sensor adjusted than ok	09:30:00	09:55:00	BRS kept in ckt,belt offcentering
10	WT	OT 4	D2 pgf4 fault acted	reset	12:30:00	12:55:00	