



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 67	OLR acted	reset	05:45:00	05:50:00	
2	OHP	cO 29	E PB not released,E push button and P/C fuse blown ,in cjb	fuse replaced,P/C bypassed in CJB	04:10:00	04:30:00	P/C having e/f,
3	OHP	CO 29	OLR acted	reset	00:10:00	00:20:00	
4	OHP	TBS on CO 5A	LT not working,M4 tripped continuously	M4 removed	22:30:00	22:40:00	to be checked
5	OHP	BRC on Co 28	b/w 2 working,	b/w 2 chain slipped,informed mechanical	03:00:00	03:10:00	
6	CHP	CC 51	mPD tripped 4 times	reset	04:45:00	05:20:00	
7	CHP	CC 52	mpd tripped	reset	03:50:00	03:55:00	
8	CHP	CC 51A	tripped due to jamming	reset	23:00:00	23:05:00	
9	CHP	JH 17	lighting complaint,neutral missing	rectified	22:30:00	22:50:00	
10	CHP	CC 40 SCR2	LT not working,Ot acted	released OT	00:00:00	00:15:00	
11	CHP	CC 31 SCR4	B/W not working,return filter problem	informed mechanical	00:00:00	00:15:00	
12	CHP	CC 39	TUL CS acted	checked found all ok	00:25:00	00:40:00	
13	CHP	CC 125	olr acted	reset	01:10:00	01:15:00	
14	CHP	CC 38 SCR6	LT not working,M2 tripped	reset	02:15:00	02:30:00	
15	CHP	CC 40 SCR2	luff not working,oil level low	informed mechanical	02:45:00	03:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 30/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 34 SCr1	LT not working,drive tripped,Ot acted,m5,6,7 OLR acted	reset	05:20:00	05:45:00	
17	CHP	CC 105 scr 10	pcrd cable fallen	PCRD cable winding done	01:22:00	01:35:00	
18	IOSA	Oc 19 A	ZSS complaint,probe damaged	probe replaced	04:45:00	05:40:00	material jamming,operation was cleaning the jamming