



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 12/02/2026

Area: WT

Equipment	Job
OP 10 jobs	Mast placed and alignment done (welding work is going on)
OP 10 jobs	Old panel stools removed and made new stool and placed D B Rs
OP 10 jobs	D1 Motor cable jointing done and 1 no D B R shifted from new building
EOT Crane(O)	Main Hoist ,brake rectifier replaced
OP 2 , 3 and 6	After rake maintenance done