



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/11/2025

Area: CHP

| Equipment          | Job   |
|--------------------|---|
| JH 8,9,10          | Hoist panels PPM was done   |
| CC 222/223         | Belt Scale interlock analog card connections done, programming done for testing purpose |
| CC 25              | PPM was done  |
| Coal complex,CM 17 | Rooms cleaning was done   |
| SCR 2,3,6,7        | Instrumentation sensors maintenance was done  |
| CC 213 High Mast   | Mast lifted and installed,cables laid,lamp fixtures ring assembled and fixed            |
| SCR 2              | PCRD resistance contactors replaced   |
| S 1,SCR 2          | 2 nos machine shiftings were done   |