



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on Co 28	b/w not rotating, control mcb is in off condition	made on	06:20:00	06:35:00	
2	OHP	CO 26	olr acted	reset	09:15:00	09:25:00	
3	OHP	TBS on Co 7A	luffing not working, up limit stucked	limit released	08:50:00	09:05:00	
4	OHP	WOBR on co 25	luff down ok, up not working, solenoid not picked up 12 v voltage	all control wire checked and tightened, finally 24 v came	08:15:00	08:45:00	no delay, talk to operator tell them to convey when up required we will do manually
5	OHP	CO 19	zss acted, probe wire got cut	jointed	07:45:00	07:56:00	
6	OHP	CR 1A	not running, filter clogged problem	bypassed as per operation instruction	08:00:00	08:15:00	
7	OHP	co 50	olr acted	reset	06:15:00	06:25:00	
8	CHP	CC 117	olr acted 4 times	reset	08:20:00	12:30:00	
9	CHP	CC 51	mpd tripped 5 times	reset	08:00:00	13:45:00	
10	CHP	CC 54	olr acted 5 times	reset	10:30:00	13:45:00	
11	CHP	CC 131	olr acted	reset	07:20:00	07:25:00	
12	CHP	CC 104 scr9	slew not working, mpcb tripped	made it on	07:30:00	07:45:00	
13	CHP	cc 40 SCR2	slew not working, jamming	informed operation	08:59:00	09:10:00	





वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/12/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 31 SCR4	operator cabin side no lighting, mcb tripped	made on	11:30:00	11:40:00	