



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/01/2026

Area: OHP

Equipment	Job
om-15,16,24	mcc rooms house keeping is done.
losp-2 ; co-10a, rsco-1a, rco-6a, bf-3a, 4a, 5a, vf-1a, 2a, vs-1, 2a, 3a, 4a, 5a, bf-1a, 2a, 7a, 8a, 9a	motor and panel side ppm is done
co-7 pullchord	earth fault is rectified, to be kept in circuit when conveyor stops.
brc-2 shifting	shifted from repair bay to co-30
brc-1 shifting	shifted from co-30 to co-8a
For brc-1 on co-30 b/w-1	spare motor trail run is taken at hvmmcc-1
co-58	motor and panel side ppm is done.