



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 04/09/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 65	E PB problem	pb replaced	11:00:00	11:20:00	
2	OHP	TBS on CO 22	LT not working,brake not released stucked	brake released than ok	09:00:00	09:20:00	
3	OHP	BRC on CO 32	LT not taking place,drive trips due to ol	reset	13:30:00	13:45:00	
4	CHP	CC 32 scr 5	slew not taking place,slew limit acted	released	07:30:00	07:40:00	
5	CHP	CC 39 SCR 7	signal missing,modem not pinging,EOP adaptor module @ near modem not working	EOP adaptor replaced,LT done than ok	08:10:00	08:50:00	
6	CHP	CC 32 SCR 5	LT not taking place,drive overload	reset	09:10:00	09:20:00	
7	CHP	CC 31 R1	b/c not running,zss cage stucked	cage made free	09:10:00	09:20:00	
8	CHP	CC 112	BRS acted not reset	sensor cleaned and adjusted	10:30:00	10:40:00	
9	CHP	CC 36 SCR1	LT not working,m2 mpcb trips	made it on	12:25:00	12:35:00	
10	CHP	CC 29	olr acted	reset	08:05:00	08:10:00	
11	CHP	CC 21(C)	OLR acted	reset	07:15:00	07:30:00	
12	CHP	CC 51	mpd trips	reset	07:45:00	07:50:00	3 times
13	WT	OT 3	d2 trips due to encoder fault	reset	08:50:00	09:00:00	
14	WT	CC 3(b)	trips due to jamming	mpcb made on	09:50:00	09:55:00	
15	IOSA	WOBR NEW	b/w pump not getting on,oil level low	informed mech	12:30:00	12:40:00	